

**सिपेट : सेन्टर फॉर स्किलिंग एण्ड  
टेक्निकल सपोर्ट (सी एस टी एस)**

रसायन एवं पेट्रोसायन विभाग,  
रसायन एवं उर्वरक मंत्रालय, भारत सरकार  
एस.पी.-1298, सीतापुरा औद्योगिक क्षेत्र,  
फेज-III, टोंक रोड, जयपुर-302 022  
फोन : +91-141-2770264 / 65 / 66, 2770664  
फैक्स : +91-141-2770736

ई-मेल : jaipur@cipet.gov.in; cipet\_jaipur@yahoo.co.in

वेबसाइट : www.cipet.gov.in

मुख्यालय : सिपेट, गिन्डी, चैन्नई-600 032



CIPET सि पेट  
probe - perform - practice - Plastics



**CIPET : CENTRE FOR SKILLING AND  
TECHNICAL SUPPORT (CSTS)**

Department of Chemicals & Petrochemicals  
Ministry of Chemicals & Fertilizers, Govt. of India  
SP-1298, Sitapura Industrial Area,  
Phase-III, Tonk Road, Jaipur-302 022  
Ph. : +91-141-2770264/65/66, 2770664  
Fax : +91-141-2770736

E-mail : jaipur@cipet.gov.in; cipet\_jaipur@yahoo.co.in

Website : www.cipet.gov.in

Head Office : CIPET, Guindy, Chennai-600 032

**PLASTICS TESTING CENTRE**

**TEST CERTIFICATE**

**Issued to:**

**M/s. Enertrak Instruments Pvt. Ltd.  
IT-3, EPIP, RIICO Industrial Area,  
Sitapura, Jaipur**

**TEST REPORT NO. : 1737**

**Dated : 27.02.2019**

Your Ref. No. & Dated : Dt. 13.02.2019

W.O. No. : 1730

Test Report as per Standard: As mentioned in "Part - C"

**PART - A**

**PARTICULARS OF SAMPLE SUBMITTED**

- |  |  |
|--|--|
| a) Name of Sample                      | : Meter & Genset Controller            |
| b) Grade/Variety/Type/Size/Class       | : --                                   |
| c) Declared Value, if any              | : --                                   |
| d) Code No.                            | : --                                   |
| e) Batch No. and Date of Manufacturing | : --                                   |
| f) Quantity                            | : 03 Nos. each & Power Supply : 01 No. |
| g) Mode of Packing                     | : --                                   |
| h) Sealed or not                       | : --                                   |
| i) Date of Receipt                     | : 15.02.2019                           |
| j) Date of completion                  | : 27.02.2019                           |
| k) Any other information               | : --                                   |

**PART - B**

**SUPPLEMENTARY INFORMATION**

- |      |  |       |
|------|--|-------|
| i.   | Reference to sampling procedure  | : NIL |
| ii.  | Supporting documents for the measurement taken and result derived                | : NIL |
| iii. | Deviation from the test method as prescribed in relevant work instruction if any | : NIL |



*Ambil G*  
Page 1 of 3

केन्द्र : अहमदाबाद, अमृतसर, औरंगाबाद, अगस्तला, बदी, बालासोर, बेंगलुरु, भोपाल, भुवनेश्वर, चंद्रपुर, चेन्नई, देहरादून, गुवाहाटी, गुरुग्राम, ग्वालियर, हैदराबाद, हाजीपुर, हल्दिया, इम्फाल, जयपुर, कोच्ची, लखनऊ, मदुरै, मुरथल, मैसूरु, रायपुर, राँची, वलसाड एवं विजयवाड़ा

Centres : Ahmedabad, Amritsar, Aurangabad, Agartala, Baddi, Balasore, Bengaluru, Bhopal, Bhubaneswar, Chandrapur, Chennai, Dehradun, Guwahati, Gurugram, Gwalior, Hyderabad, Hajipur, Haldia, Imphal, Jaipur, Kochi, Lucknow, Madurai, Murthal, Mysuru, Raipur, Ranchi, Valsad & Vijayawada

**सिपेट : सेन्टर फॉर स्किलिंग एण्ड  
टेक्निकल सपोर्ट (सी एस टी एस)**

रसायन एवं पेट्रोसायन विभाग,  
रसायन एवं उर्वरक मंत्रालय, भारत सरकार  
एस.पी.-1298, सीतापुरा औद्योगिक क्षेत्र,  
फेज-III, टोंक रोड, जयपुर-302 022  
फोन : +91-141-2770264 / 65 / 66, 2770664  
फैक्स : +91-141-2770736  
ई-मेल : jaipur@cipet.gov.in; cipet\_jaipur@yahoo.co.in  
वेबसाइट : www.cipet.gov.in  
मुख्यालय : सिपेट, गिण्डी, चैन्नई-600 032



**CIPET सि पेट**  
probe - perform - practical - plastic



**CIPET : CENTRE FOR SKILLING AND  
TECHNICAL SUPPORT (CSTS)**

Department of Chemicals & Petrochemicals  
Ministry of Chemicals & Fertilizers, Govt. of India  
SP-1298, Sitapura Industrial Area,  
Phase-III, Tonk Road, Jaipur-302 022  
Ph. : +91-141-2770264/65/66, 2770664  
Fax : +91-141-2770736  
E-mail : jaipur@cipet.gov.in; cipet\_jaipur@yahoo.co.in  
Website : www.cipet.gov.in  
Head Office : CIPET, Guindy, Chennai-600 032

**TEST REPORT NO. : 1737**

**Dated : 27.02.2019**

**PART - C  
TEST RESULTS**

**Sample: (A) Meter & Genset Controller ( EDGC 6600R)**

S. No.	Clause	Name of the Test	Test Method	Unit	Specified Requirements	Test Value
01.	---	Environmental Testing @ 70°C for 48 hrs	SOP	--	--	The instrument is working / functional after the test condition.
02.	---	Damp Heat Test @ 45°C & Relative humidity 80°C for 24 hrs.	SOP	---	--	The instrument is working / functional after the test condition.
03	---	Low temp. Test for 2 hrs. at -10°C	SOP	---	--	The instrument is working / functional after the test condition.
04.	---	Vibration Test 50Hz acceleration for 2 hrs.	SOP	---	--	The instrument is working / functional after the test condition.

**Sample(B) Meter & Genset Controller ( TEC 9900C)**

S. No.	Clause	Name of the Test	Test Method	Unit	Specified Requirements	Test Value
01.	---	Environmental Testing @ 70°C for 48 hrs	SOP	--	--	The instrument is working / functional after the test condition.
02.	---	Damp Heat Test @ 45°C & Relative humidity 80°C for 24 hrs.	SOP	---	--	The instrument is working / functional after the test condition.
03	---	Low temp. Test for 2 hrs. at -10°C	SOP	---	--	The instrument is working / functional after the test condition.
04.	---	Vibration Test 50Hz acceleration for 2 hrs.	SOP	--	--	The instrument is working / functional after the test condition.

*Ambika*  
Page 2 of 3



केन्द्र : अहमदाबाद, अमृतसर, औरंगाबाद, अगरतला, बदी, बालासोर, बेंगलुरु, भोपाल, भुवनेश्वर, चण्डीपुर, चैन्नई, देहरादून, गुवाहाटी, गुरुग्राम, ग्वालियर, हैदराबाद, हाजीपुर, हल्दिया, इम्फाल, जयपुर, कोच्ची, लखनऊ, मदुरै, मुम्बई, मुश्नल, मैसूरु, रायपुर, राँची, वलसाड एवं विजयवाडा

Centres : Ahmedabad, Amritsar, Aurangabad, Agartala, Baddi, Balasore, Bengaluru, Bhopal, Bhubaneswar, Chandrapur, Chennai, Dehradun, Guwahati, Gurugram, Gwalior, Hyderabad, Hajipur, Haldia, Imphal, Jaipur, Kochi, Lucknow, Madurai, Murthal, Mysuru, Raipur, Ranchi, Valsad & Vijayawada

**सिपेट : सेन्टर फॉर स्किलिंग एण्ड  
टेक्निकल सपोर्ट (सी एस टी एस)**

रसायन एवं पेट्रोरसायन विभाग,  
रसायन एवं उर्वरक मंत्रालय, भारत सरकार  
एस.पी.-1298, सीतापुरा औद्योगिक क्षेत्र,  
फेज-III, टोंक रोड, जयपुर-302 022  
फोन : +91-141-2770264 / 65 / 66, 2770664  
फैक्स : +91-141-2770736  
ई-मेल : jaipur@cipet.gov.in; cipet\_jaipur@yahoo.co.in  
वेबसाइट : www.cipet.gov.in  
मुख्यालय : सिपेट, गिण्डी, चैन्नई-600 032



**CIPET : CENTRE FOR SKILLING AND  
TECHNICAL SUPPORT (CSTS)**

Department of Chemicals & Petrochemicals  
Ministry of Chemicals & Fertilizers, Govt. of India  
SP-1298, Sitapura Industrial Area,  
Phase-III, Tonk Road, Jaipur-302 022  
Ph. : +91-141-2770264/65/66, 2770664  
Fax : +91-141-2770736  
E-mail : jaipur@cipet.gov.in; cipet\_jaipur@yahoo.co.in  
Website : www.cipet.gov.in  
Head Office : CIPET, Guindy, Chennai-600 032

**TEST REPORT NO. : 1737**

**Dated : 27.02.2019**

**PART - C  
TEST RESULTS**

**Sample: (C) Meter & Genset Controller ( TEM 800)**

S. No.	Clause	Name of the Test	Test Method	Unit	Specified Requirements	Test Value
01.	---	Environmental Testing @ 70°C for 48 hrs	SOP	--	--	The instrument is working / functional after the test condition.
02.	---	Damp Heat Test @ 45°C & Relative humidity 80°C for 24 hrs.	SOP	---	--	The instrument is working / functional after the test condition.
03	---	Low temp. Test for 2 hrs. at -10°C	SOP	---	--	The instrument is working / functional after the test condition.
04.	---	Vibration Test 50Hz acceleration for 2 hrs.	SOP	--	--	The instrument is working / functional after the test condition.

**PART - D:**

**REMARKS : NIL**

**NOTE :**

1. The results related only to the items tested as supplied by the party.
2. The test certificate shall not be reproduced in full/part except without the written approval of the laboratory.

*Ambika*

**AUTHORIZED SIGNATORY**  
Ambika Joshi (Technical Manager)

*Irfan Ahmad Mir*

**AUTHORIZED SIGNATORY**  
Dr. Irfan Ahmad Mir (Sr. Technical Officer)

Page 3 of 3




केन्द्र : अहमदाबाद, अमृतसर, औरंगाबाद, अगरतला, बदी, बालासोर, बेंगलुरु, भोपाल, भुवनेश्वर, चंद्रपुर, चैन्नई, देहरादून, गुवाहाटी, गुरुग्राम, ग्वालियर, हैदराबाद, हाजीपुर, हल्दिया, इम्फाल, जयपुर, कोच्ची, लखनऊ, मदुरै, मुम्बई, मेसूरु, रायपुर, राँची, वलसाड एवं विजयवाड़ा

Centres : Ahmedabad, Amritsar, Aurangabad, Agartala, Baddi, Balasore, Bengaluru, Bhopal, Bhubaneswar, Chandrapur, Chennai, Dehradun, Guwahati, Gurugram, Gwalior, Hyderabad, Hajipur, Haldia, Imphal, Jaipur, Kochi, Lucknow, Madurai, Murthal, Mysuru, Raipur, Ranchi, Valsad & Vijayawada

**सिपेट : सेन्टर फॉर स्किलिंग एण्ड  
टेक्निकल सपोर्ट (सी एस टी एस)**

रसायन एवं पेट्रोरसायन विभाग,  
रसायन एवं उर्वरक मंत्रालय, भारत सरकार  
एस.पी.-1298, सीतापुरा औद्योगिक क्षेत्र,  
फेज-III, टोंक रोड, जयपुर-302 022  
फोन : +91-141-2770264 / 65 / 66, 2770664  
फैक्स : +91-141-2770736  
ई-मेल : jaipur@cipet.gov.in; cipet\_jaipur@yahoo.co.in  
वेबसाइट : www.cipet.gov.in  
मुख्यालय : सिपेट, गिण्डी, चैन्नई-600 032



**CIPET : CENTRE FOR SKILLING AND  
TECHNICAL SUPPORT (CSTS)**

Department of Chemicals & Petrochemicals  
Ministry of Chemicals & Fertilizers, Govt. of India  
SP-1298, Sitapura Industrial Area,  
Phase-III, Tonk Road, Jaipur-302 022  
Ph. : +91-141-2770264/65/66, 2770664  
Fax : +91-141-2770736  
E-mail : jaipur@cipet.gov.in; cipet\_jaipur@yahoo.co.in  
Website : www.cipet.gov.in  
Head Office : CIPET, Guindy, Chennai-600 032

CIPET: CSTS/Jaipur/PTC/2018-19/

Date: 01.03.2019

To,

**M/s. Enertrak Instruments Pvt. Ltd.  
IT-3, EPIP, RIICO Industrial Area,  
Sitapura, Jaipur**

**Subject: Clarification letter against Test Report No. 1737, Dated. 27.02.2019 - Reg.**

Dear Sir,


With reference to your letter dt. 13.02.2019 regarding the above subject matter, In Test Report No. 1737 dated 27.02.2019 Page No. 2 of 3 & 3 of 3 serial No. 2, Relative Humidity of Meter & Genset Controller has been mistakenly typed as 80°C instead of 80% RH under Name of the Test.

Therefore, you are requested to read the same as 80% RH instead of 80°C.

This is submitted for your kind information.

Inconvenience caused is regretted.

Thanking You,

  
Authorized Signatory  
Dr. Irfan Ahmad Mir  
