



सूक्ष्म, लघु एवं मध्यम उद्यम
MICRO, SMALL & MEDIUM ENTERPRISES
MSME - TECHNOLOGY DEVELOPMENT CENTRE,
MUMBAI

वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई
INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI

भारत सरकार की सोसाईटी
सूक्ष्म, लघु एवं मध्यम उद्यम मंत्रालय
Government of India Society
Ministry of Micro, Small & Medium Enterprises



WO/ETL/041/18-19

संदर्भ सं. / Ref. No.

दिनांक 14.06.2018

Date :

M/s. ENERTRAK INSTRUMENTS PVT. LTD.
IT-3,EPIP,RIICO INDUSTRIAL AREA,
SITAPURA,JAIPUR,
RAJASTHAN-302 020, INDIA

Kind Attn : Mr. Rajesh Sharma

विषय : परिक्षण रिपोर्ट
Sub : Test Report

TR/ETL/058/18-19

महोदय,

आपके उपकरणों / अवयवों पर किये हुये परिक्षण रिपोर्ट संख्या () आपको जानकारी के लिए पत्र के साथ भेज रहे हैं। यदि आपको परिक्षीत मदों पर स्पष्टीकरण की कोई आवश्यकता हो तो, कृपया परिक्षण रिपोर्ट जारी करने वाले प्राधिकारी को हमारे संदर्भ संख्या और तारीख का उल्लेख करते हुए, रिपोर्ट प्राप्त होने पर चार सप्ताह के अन्दर सम्पर्क करें अथवा लिखें। हम इस पत्र के साथ फीड बैक फॉर्म भेज रहे हैं। कृपया उसे भरके प्रधाननिदेशक, वैमाउअसं को भेजे।

धन्यवाद!

भवदीय

(Signature)
प्रधान निदेशक

संलग्न पत्रानुसार

Dear Sir,

TR/ETL/058/18-19

Test Report No. () / on your instruments/ Components/ Equipments are / is enclosed herewith for your information. If you need any clarification on Test Report, please write/contact Test Report issuing officer quoting our reference and date within 4 weeks from the date of receipt of this report. We are also enclosing here with feed back form. Kindly fill up and send to the Principal Director of IDEMI
Thanking you,

Yours faithfully

Encl. As above

(Signature)
PRINCIPAL DIRECTOR

Swatantryaveer Tatya Tope Marg, Chunabhatti, Sion P.O. Mumbai - 400 022. (M.S)

Phone : (022) - 2405 0301/2/3/4 Fax : (022) - 2405 0016.

• Website : www.idemi.org / msmetdcmumbai.org • Email : idemi@vsnl.net, idemi@rediffmail.com

TEST REPORT

Accreditation Field: Electrical Testing
Accreditation Valid upto : 23.04.2019
Work Order No. : WO/ETL/041/18-19
Date : 29.05.2018

NABL Accreditation No. : TC-5538
Test Report No. : TR/ETL/058/18-19
Date of Testing : 02.06.2018 to 14.06.2018
Page No. 1 of 12

Test Item : 3 Phase Multifunction Meter

Tested for: M/s : Enertrak Instruments Pvt.Ltd.
IT-3,EPIP,RIICO Industrial Area,Sitapura,Jaipur,Rajasthan-302 020,India.

Tested at : M/s.IDEMI MUMBAI


Specification of Items Under Test	Specification of Standards Used
Manufacturer : M/s. Enertrak Instruments Pvt. Ltd., Jaipur Condition of Item on receipt : Good Range /Rating : Aux Supply : 40-300 V AC Ph-N I/P Voltage : 80-600 V AC L-L Current : (-/5) Amp Model: TMF Sr. No: 268637 Class :1.0	1 Energy Meter Test System Model No.: MT 3000,Sr. No.: ID 11054 Calibration valid upto : Jan 2019 2 Electrical safety analyzer Model No.: Guardian 6100plus,Sr. No.: 10112754 Calibration valid upto : Dec 2018 3 Vibration Test System i. Vibration Test System Model : SPARK - USB, Sr. No.: 10652 Calibration Validity : July 2018 ii. Charge Accelerometer Model : 357BO3, Sr. No.: 28580 Calibration Validity : March 2020 4 Portable Power /Energy Ref. Standard Model : RD-31-203,Sr. No.:301682 Calibration valid upto : Dec 2019 Traceability: Standard use are traceable to International Standards

Ambient Conditions :

Temperature : $25 \pm 2.5^{\circ}\text{C}$ Relative Humidity : 35% to 65%

Remarks : Please refer page 2 to 12 for Test Results.

1) Procedure of Test : The above mentioned item is tested as per IS 13875 & Customer requirement.



C. M. PATIL
ASSISTANT DIRECTOR
AUTHORISED SIGNATORY

(Note : This report refers only to the particular item(s) submitted for testing. The report should not be reproduced except in full without the prior permission from the Principal Director IDEMI, Mumbai - 400 022)



A GOVERNMENT OF INDIA SOCIETY
MINISTRY OF MICRO, SMALL & MEDIUM ENTERPRISES

वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान

Institute for Design of Electrical Measuring Instruments

SWATANTRYAVEER TATYA TOPE MARG, CHUNABHATTI, SION P.O. MUMBAI - 400 022.

स्वातंत्र्यवीर तात्या टोपे मार्ग, चुनाभट्टी, सायन डाकघर, मुंबई - ४०० ०२२.



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.

INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.



ELECTRICAL TESTING LABORATORY

Sr. No.: 268637


Date of Testing: 02.06.2018 to 14.06.2018


Test Report No.: TR/ETL/058/18-19

Page No.: 2 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

Sr. No	Clause No.	Test	Test Condition	Test Requirement / Limits	Observation	Remarks
1		Insulation Resistance	500V DC applied for 1min between all terminals shorted together & body & IR value is measured	Not less than 5 MΩ	49.9 GΩ	Complied
2		High Voltage Test	2 kV AC, 50Hz for 1 min is applied between all terminals shorted together & body	No Flash over or Breakdown shall occur	No flash over or break down occurred	Complied


TESTED BY


CHECKED BY



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.

INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.



ELECTRICAL TESTING LABORATORY

Sr. No.: 268637

Date of Testing: 02.06.2018 to 14.06.2018

Test Report No.: TR/ETL/058/18-19

Page No.: 3 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

Sr. No	Clause No.	Test	Test Condition	Test Requirement / Limits	Observation	Remarks			
3	3.2	Intrinsic Error Test	At reference condition apply sufficient excitation to each at least five equidistant scale mark	Not to exceed class index of 1 % of Full scale	Std Reading	Measured Reading	Complied		
					Volts	R		Y	B
					100.00	99.9		99.8	100.2
					200.00	199.8		199.8	200.2
					300.00	300.3		300.1	300.0
					400.00	399.8		398.7	399.9
					500.00	500.1		500.3	500.1
					600.00	600.2		599.9	600.1
					Ampere	L1		L2	L3
					1.000	1.001		1.000	1.002
					2.000	1.999		2.003	1.997
					3.000	2.999		3.004	2.996
					4.000	3.998		4.005	3.995
					5.000	5.008		5.015	5.003
					Frequency@230 Volts				
					45.00	45.00			
					50.00	50.00			
					55.00	54.99			
					60.00	60.04			
					PF				
					Lag				
					0.2	0.197		0.200	0.202
					0.5	0.497		0.499	0.502
					0.8	0.798		0.800	0.801
					1.0	0.999		1.000	0.999
					Lead				
					0.8	-0.801		-0.799	-0.798
					0.5	-0.502		-0.499	-0.497
					0.2	-0.203		-0.199	-0.197
					0.0	-0.003		0.000	-0.002
					Wattage @ 5A, Upf				
					kW	kW			
					3.00	2.97			
					2.27	2.26			
					1.5	1.49			
					1.2	1.19			
					0.6	0.597			
					0.4	0.398			
					(E) % Error at pF				
					Load in %/ Amps	Upf		0.866 Lag	0.5 Lag
					100	-0.001		0.000	0.001
					50	-0.001		0.001	0.001
					20	0.000		0.001	0.002
					10	0.000		0.001	0.002
					5	0.001		-0.001	0.002

TESTED BY

CHECKED BY



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.

INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.



ELECTRICAL TESTING LABORATORY

Sr. No.: 268637

Date of Testing: 02.06.2018 to 14.06.2018

Test Report No.: TR/ETL/058/18-19

Page No.: 4 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

Sr. No	Clause No.	Test	Test Condition	Test Requirement / Limits	Observation	Remarks
--------	------------	------	----------------	---------------------------	-------------	---------

4	3.6	Influence effect resulting from a change in position	a.) Take the error value (BR) at 90 % of the full scale value	Not to exceed 50% of Class index	Std Reading		Measured Reading		Complied
					Reference value (B _R)				
					V	L1-L2	L2-L3	L3-L1	
					540.2	540.7	540.7	540.8	
					A	L1	L2	L3	
					5.001	5.000	5.002	4.999	
					Influential value (B _x)				
					V	L1-L2	L2-L3	L3-L1	
					540.2	540.7	540.7	540.9	
					A	L1	L2	L3	
					5.001	5.000	5.002	4.999	
					The difference is within limits				

TESTED BY

CHECKED BY



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.
INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.



ELECTRICAL TESTING LABORATORY

Sr. No.: 268637

Date of Testing: 02.06.2018 to 14.06.2018

Test Report No.: TR/ETL/058/18-19

Page No.: 5 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

Sr. No	Clause No.	Test	Test Condition	Test Requirement / Limits	Observation	Remarks
--------	------------	------	----------------	---------------------------	-------------	---------

					Std Reading		Measured Reading			
5	3.8	Influence effect resulting from the supply voltage	a)	Take the error value (BR) at 90 % of the full scale value	Not to exceed 100% of Class index	Reference value (B_R)				Complied
						V	L1-L2	L2-L3	L3-L1	
						540.10	540.8	540.7	540.7	
						A	L1	L2	L3	
						5.001	5.000	5.001	4.998	
						Influential value (B_{xo}) at lower limit				
						V	L1-L2	L2-L3	L3-L1	
						540.10	540.08	540.7	540.8	
						A	L1	L2	L3	
						5.001	4.999	5.001	4.998	
						Influential value (B_{xu}) at upper limit				
						V	L1-L2	L2-L3	L3-L1	
						540.1	540.8	540.7	540.9	
						A	L1	L2	L3	
						5.000	5.000	5.002	4.999	
						The difference is within limits				
			d)	Calculate the difference between B_{xo} or B_{xu} and BR						

TESTED BY

CHECKED BY



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.
INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.



ELECTRICAL TESTING LABORATORY

Sr. No.: 268637

Date of Testing: 02.06.2018 to 14.06.2018

Test Report No.: TR/ETL/058/18-19

Page No.: 6 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

Sr. No	Clause No.	Test	Test Condition	Test Requirement / Limits	Observation	Remarks					
6	4.9.1 (Part1)	Shock test	a.) Take the error value (BR) at 90 % of the full scale value	No damage shall occur to the measuring instrument during tests. After the test the error shall be within limits	Std Reading		Measured Reading		Complied		
					Reference value (BR)						
					V	L1-L2	L2-L3	L3-L1			
					540.2	540.8	540.7	540.9			
					A	L1	L2	L3			
					5.000	5.001	5.003	5.000			
					Influential value (Bx)						
					V	L1-L2	L2-L3	L3-L1			
					540.2	540.8	540.7	540.9			
					A	L1	L2	L3			
					5.001	5.000	5.001	4.998			
					No mechanical damage was observed during & after the test. The error is within limits.						



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.

INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.



ELECTRICAL TESTING LABORATORY

Sr. No.: 268637

Date of Testing: 02.06.2018 to 14.06.2018

Test Report No.: TR/ETL/058/18-19

Page No.: 7 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

Sr. No	Clause No.	Test	Test Condition	Test Requirement / Limits	Observation	Remarks					
7	4.9.2 (part1)	Vibration test	a.) Take the error value (BR) at 90 % of the full scale value	No damage shall occur to the measuring instrument during tests. After the test the error shall be within limits	Std Reading		Measured Reading		Complied		
					Reference value (B _R)						
					V	L1-L2	L2-L3	L3-L1			
					540.3	540.8	540.6	540.7			
					A	L1	L2	L3			
					5.002	5.000	5.002	4.999			
					Influential value (B _x)						
					V	L1-L2	L2-L3	L3-L1			
					540.1	540.7	540.8	540.7			
					A	L1	L2	L3			
					5.000	4.999	5.001	5.001			
					No mechanical damage was observed during & after the test. The error is within limits.						
					b.) Subject the EUT to vibration according to IS 9000 (part 8)	No damage shall occur to the measuring instrument during tests. After the test the error shall be within limits					
c) After the test verify for any damage. Check the error (B _x) at 90 % of the full scale value.	No damage shall occur to the measuring instrument during tests. After the test the error shall be within limits										

TESTED BY

CHECKED BY



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.

INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.



ELECTRICAL TESTING LABORATORY

Sr. No.: 268637

Date of Testing: 02.06.2018 to 14.06.2018

Test Report No.: TR/ETL/058/18-19

Page No.: 8 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

Sr. No	Clause No.	Test	Test Condition	Test Requirement / Limits	Observation	Remarks			
8	3.13 (Part2)	Frequency influence error in the case of a.c. voltage measurement	a.) Take the error value (BR) at 90 % of the full scale value for the a.c voltage at reference frequency	The change in error shall be within limits specified by manufacturer	Std Reading	Measured Reading	Complied		
					Reference value (B _R)				
					V	L1-L2		L2-L3	L3-L1
					540.3	540.8		539.9	540.8
			A		L1	L2		L3	
			5.000		5.001	5.002		5.000	
			Influential value (B _x)						
			V		L1-L2	L2-L3		L3-L1	
			540.2		540.7	540.7		540.9	
			A		L1	L2		L3	
			5.001		5.000	5.003		4.999	
			c.) Calculate the difference between B _x and BR		The difference is within limits				

TESTED BY

CHECKED BY



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.

INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.



ELECTRICAL TESTING LABORATORY

Sr. No.: 268637

Date of Testing: 02.06.2018 to 14.06.2018

Test Report No.: TR/ETL/058/18-19

Page No.: 9 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

Sr. No	Clause No.	Test	Test Condition	Test Requirement / Limits	Observation	Remarks
--------	------------	------	----------------	---------------------------	-------------	---------

					Std Reading	Measured Reading				Complied
9	3.15 a) (Part2)	Permanent overload	a.) Take the error value (BR) at 90 % of the full scale value	No damage shall occur to the measuring instrument during tests. After the test the error shall be within limits	Reference value (B _R)					
					V	L1-L2	L2-L3	L3-L1		
			540.3		540.8	540.8	540.9			
			A		L1	L2	L3			
			5.001		5.001	5.002	4.999			
			Influential value (B _x)							
			V		L1-L2	L2-L3	L3-L1			
			540.0		540.7	540.6	540.8			
			A		L1	L2	L3			
			5.001		5.002	5.001	4.999			
			The difference is within limits No mechanical damage was observed during & after the test. The error is within limits.							
			b.) Subject the EUT to overload of 120 % in all ranges for a minimum of 2 hours.							
			c.) Check the error (B _{xu}) at 90 % of the full scale value.							
			d.) Calculate the difference between B _x and BR							

TESTED BY

CHECKED BY



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.
INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.



ELECTRICAL TESTING LABORATORY

Sr. No.: 268637

Date of Testing: 02.06.2018 to 14.06.2018

Test Report No.: TR/ETL/058/18-19

Page No.: 10 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

Sr. No	Clause No.	Test	Test Condition	Test Requirement / Limits	Observation	Remarks
--------	------------	------	----------------	---------------------------	-------------	---------

					Std Reading	Measured Reading			Complied
10	3.15 b) (Part2)	Short-time overload	a) Take the error value (BR) at 90 % of the full scale value	A fuse, if any, may operate. No damage shall occur to the measuring instrument during tests. After the test the error shall be within limits	Reference value (B _R)				
					V	L1-L2	L2-L3	L3-L1	
					540.1	540.7	540.6	540.7	
					A	L1	L2	L3	
			5.000		4.999	5.000	4.997		
			Influential value (B _{XU})						
			V		L1-L2	L2-L3	L3-L1		
			540.2		540.8	540.6	540.8		
			A		L1	L2	L3		
			5.001		5.000	5.001	4.999		
			The difference is within limits						
			No mechanical damage was observed during & after the test. The error is within limits.						
			b). Subject the EUT once to given overload of 0.5 seconds in all ranges.						
c) Check the error (B _{xu}) at 90 % of the full scale value.									
d) Calculate the difference between B _{xu} and BR									

TESTED BY

CHECKED BY



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.
INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.



ELECTRICAL TESTING LABORATORY

Sr. No.: 268637

Date of Testing: 02.06.2018 to 14.06.2018

Test Report No.: TR/ETL/058/18-19

Page No.: 11 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

Sr. No	Clause No.	Test	Test Condition	Test Requirement / Limits	Observation	Remarks
--------	------------	------	----------------	---------------------------	-------------	---------

11	3.16 (Part2)	Self Heating due to measured Quantity test.	a) Keep the EUT in a switched-on condition for at least two hours at reference temperature, but without a measured quantity applied.	The error shall be within the class index.					Complied					
			b) Apply measuring quantity with approximately 90 % of the full scale value.											
			c) Note down the displayed value after the elapse of one minute (BR).											
			d) Keep the EUT for 30 minutes with input quantity applied.											
			e) Note down the displayed value after the elapse of 30 minutes.											
			f) Calculate the self heating influence error Bx-BR											
			Std Reading				Measured Reading							
			Reference value (B _R)											
			V				L1-L2			L2-L3		L3-L1		
			540.2				540.8			540.8		540.7		
A				L1		L2		L3						
5.001				5.001		5.002		4.999						
Influential value (B _x)														
V				L1-L2		L2-L3		L3-L1						
540.2				540.9		540.7		540.8						
A				L1		L2		L3						
5.002				5.001		5.003		5.000						
				The difference is within limits. The error is within class index.										

adikou
TESTED BY

[Signature]
CHECKED BY



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई-४०० ०२२.

INSTITUTE FOR DESIGN OF ELECTRICAL
MEASURING INSTRUMENTS, MUMBAI - 400 022.

ELECTRICAL TESTING LABORATORY



Sr. No.: 268637

Date of Testing: 02.06.2018 to 14.06.2018

Test Report No.: TR/ETL/058/18-19


Page No.: 12 of 12

Test Results of : 3 Phase Multifunction Meter as per IS 13875: 1993

EUT PHOTOGRAPH



NAME PLATE



END OF TEST REPORT

Sanjiv Kumar
TESTED BY

[Signature]
CHECKED BY